

MULTISPLIT DUAL 14

DU NEXVA S5 E + FU WALL NEXVA													
OUTDOOR UNIT	DUAL SPLIT 14	DS-CANM14E1											
INDOOR UNIT	WALL 9 / 12	DS-S5E1P00E1 / DS-S5E1H12E1VS-S5E1H12E1E1											
Available combinations													
Cooling		Cooling capacity					Power input			EER (kW/h)	SEER	Energy Class	
		Each room (kW)		Total (kW)			(kW)						
1 unit	FU combinations	A	B	min	nominal	max	min	rating	max	3,25	—	—	
		9	2,50	—	1,23	2,50	3,20	0,30	0,77				0,96
		12	3,50	—	1,23	3,50	3,90	0,30	1,08				1,35
	18	4,10	—	1,35	4,10	4,90	0,40	1,27	1,59				
2 units	9+9	2,05	2,05	1,76	4,10	4,92	0,44	1,27	1,59	3,23	5,60	A+	
	9+12	1,95	2,14	1,76	4,09	4,91	0,38	1,07	1,34	3,82	6,70	A++	

Available combinations															
Heating		Heating capacity					Power input			COP (kW/h)	SCOP Average Season	Energy Class Average Season	SCOP Warmer Season	Energy Class Warmer Season	
		Each room (kW)		Total (kW)			(kW)								
1 unit	FU combinations	A	B	min	nominal	max	min	rating	max	3,73	—	—	—	—	
		9	2,92	—	1,32	2,90	3,16	0,28	0,78						0,97
		12	3,75	—	1,32	3,80	4,31	0,28	1,02						1,28
	18	4,40	—	1,45	4,40	5,24	0,38	1,19	1,48						
2 units	9+9	2,20	2,20	1,89	4,40	5,28	0,42	1,19	1,48	3,71	3,8	A	—	—	
	9+12	1,90	2,51	1,91	4,44	5,33	0,36	1,02	1,28	4,14	5,9	A	5,88	A+++	

DU NEXVA S5 E + FU WALL ALTYAS													
OUTDOOR UNIT	DUAL SPLIT 14	DS-CANM14E1											
INDOOR UNIT	WALL 9 / 12	DS-S5E1P00E1 / DS-S5A1H12E1											
Available combinations													
Cooling		Cooling capacity					Power input			EER (kW/h)	SEER	Energy Class	
		Each room (kW)		Total (kW)			(kW)						
1 unit	FU combinations	A	B	min	nominal	max	min	rating	max	3,25	—	—	
		9	2,50	—	1,23	2,50	3,20	0,30	0,77				0,96
		12	3,50	—	1,23	3,50	3,90	0,30	1,08				1,35
	18	4,10	—	1,35	4,10	4,90	0,40	1,27	1,59				
2 units	9+9	2,05	2,05	1,76	4,10	4,92	0,44	1,27	1,59	3,23	6,80	A++	
	9+12	1,84	2,32	1,79	4,16	5,00	0,38	1,08	1,35	3,85	7,05	A++	

Available combinations															
Heating		Heating capacity					Power input			COP (kW/h)	SCOP Average Season	Energy Class Average Season	SCOP Warmer Season	Energy Class Warmer Season	
		Each room (kW)		Total (kW)			(kW)								
1 unit	FU combinations	A	B	min	nominal	max	min	rating	max	3,73	—	—	—	—	
		9	2,92	—	1,32	2,90	3,16	0,28	0,78						0,97
		12	3,75	—	1,32	3,80	4,31	0,28	1,02						1,28
	18	4,40	—	1,45	4,40	5,24	0,38	1,19	1,48						
2 units	9+9	2,20	2,20	1,89	4,40	5,28	0,42	1,19	1,48	3,71	4,0	A+	—	—	
	9+12	1,92	2,50	1,92	4,47	5,36	0,35	1,01	1,26	4,43	6,0	A+	5,22	A+++	

DU NEXVA S5 E + FU DUCT NEXVA													
OUTDOOR UNIT	DUAL SPLIT 14	DS-CANM14E1											
INDOOR UNIT	DUCT 9/12/18	DS-S5E1D00E1 / DS-S5E1H12E1E1 / DS-S5E1H18E1E1											
Available combinations													
Cooling		Cooling capacity					Power input			EER (kW/h)	SEER	Energy Class	
		Each room (kW)		Total (kW)			(kW)						
1 unit	FU combinations	A	B	min	nominal	max	min	rating	max	3,25	—	—	
		9	2,50	—	1,23	2,50	3,20	0,30	0,77				0,96
		12	3,50	—	1,23	3,50	3,90	0,30	1,08				1,35
	18	4,10	—	1,35	4,10	4,90	0,40	1,27	1,59				
2 units	9+9	2,05	2,05	1,76	4,10	4,92	0,44	1,27	1,59	3,23	6,10	A++	
	9+12	2,09	2,12	1,81	4,22	5,06	0,38	1,09	1,37	3,87	6,66	A++	

Available combinations															
Heating		Heating capacity					Power input			COP (kW/h)	SCOP Average Season	Energy Class Average Season	SCOP Warmer Season	Energy Class Warmer Season	
		Each room (kW)		Total (kW)			(kW)								
1 unit	FU combinations	A	B	min	nominal	max	min	rating	max	3,73	—	—	—	—	
		9	2,92	—	1,32	2,90	3,16	0,28	0,78						0,97
		12	3,75	—	1,32	3,80	4,31	0,28	1,02						1,28
	18	4,40	—	1,45	4,40	5,24	0,38	1,19	1,48						
2 units	9+9	2,20	2,20	1,89	4,40	5,28	0,42	1,19	1,48	3,71	3,8	A	—	—	
	9+12	1,92	2,50	1,92	4,47	5,37	0,35	1,01	1,26	4,44	4,3	A+	5,18	A+++	

DU NEXVA S5 E + FU CASSETTE NEXVA													
OUTDOOR UNIT	DUAL SPLIT 14	DS-CANM14E1											
INDOOR UNIT	CASSETTE 9/12/18	DS-S5E1C00E1 / DS-S5E1H12E1E1 / DS-S5E1H18E1E1											
Available combinations													
Cooling		Cooling capacity					Power input			EER (kW/h)	SEER	Energy Class	
		Each room (kW)		Total (kW)			(kW)						
1 unit	FU combinations	A	B	min	nominal	max	min	rating	max	3,25	—	—	
		9	2,50	—	1,23	2,50	3,20	0,30	0,77				0,96
		12	3,50	—	1,23	3,50	3,90	0,30	1,08				1,35
	18	4,10	—	1,35	4,10	4,90	0,40	1,27	1,59				
2 units	9+9	2,05	2,05	1,76	4,10	4,92	0,44	1,27	1,59	3,23	6,1	A++	
	9+12	1,90	2,34	1,82	4,25	5,08	0,40	1,14	1,41	3,71	6,56	A++	

Available combinations															
Heating		Heating capacity					Power input			COP (kW/h)	SCOP Average Season	Energy Class Average Season	SCOP Warmer Season	Energy Class Warmer Season	
		Each room (kW)		Total (kW)			(kW)								
1 unit	FU combinations	A	B	min	nominal	max	min	rating	max	3,73	—	—	—	—	
		9	2,92	—	1,32	2,90	3,16	0,28	0,78						0,97
		12	3,75	—	1,32	3,80	4,31	0,28	1,02						1,28
	18	4,40	—	1,45	4,40	5,24	0,38	1,19	1,48						
2 units	9+9	2,20	2,20	1,89	4,40	5,28	0,42	1,19	1,48	3,71	3,8	A	—	—	
	9+12	1,89	2,51	1,89	4,40	5,28	0,37	1,04	1,31	4,21	4,24	A+	5,50	A+++	

MULTISPLIT DUAL 18

DU NEXVA S5 E + FU WALL NEXVA													
OUTDOOR UNIT	DUAL SPLIT 18	DS-CANM18E1											
INDOOR UNIT	WALL 9 / 12	DS-S5E1P00E1 / DS-S5E1H12E1VS-S5E1H12E1E1											
Available combinations													
Cooling		Cooling capacity					Power input			EER (kW/h)	SEER	Energy Class	
		Each room (kW)		Total (kW)			(kW)						
1 unit	FU combinations	A	B	min	nominal	max	min	rating	max	3,25	—	—	
		9	2,50	—	1,43	2,50	3,20	0,25	0,75				0,93
		12	3,50	—	1,43	3,50	3,90	0,35	1,08				1,29
	18	5,00	—	1,64	5,00	5,51	0,45	1,55	1,89				
2 units	9+9	2,65	2,65	2,12	5,30	6,41	0,54	1,64	2,05	3,23	6,10	A++	
	9+12	2,27	3,03	2,12	5,17	6,41	0,54	1,38	2,05	3,76	6,75	A++	
12+12	2,65	2,65	2,12	5,28	6,41	0,54	1,38	2,05	3,82	6,94	A++		

Available combinations															
Heating		Heating capacity					Power input			COP (kW/h)	SCOP Average Season	Energy Class Average Season	SCOP Warmer Season	Energy Class Warmer Season	
		Each room (kW)		Total (kW)			(kW)								
1 unit	FU combinations	A	B	min	nominal	max	min	rating	max	3,75	—	—	—	—	
		9	3,00	—	1,56	3,00	3,63	0,32	0,80						1,00
		12	3,80	—	1,56	3,80	4,60	0,32	1,00						1,20
18	5,20	—	1,73	5,20	5,79	0,42	1,35	1,68	3,85	—	—	—			

2 units	9+9	2.78	2.78	2.23	5.57	6.68	0.51	1.50	1.88	3.71	3.80	A	5.10	A++
	9+12	2.39	3.18	2.23	5.54	6.68	0.51	1.39	1.88	3.99	4.23	A+	5.15	A++
	12+12	2.79	2.79	2.23	5.62	6.68	0.51	1.37	1.88	4.10	4.34	A+	5.28	A++
DU NEXIA S5 E+IU WALL A1X4X														
OUTDOOR UNIT	DUAL SPLIT 18	OS-CANM1218												
INDOOR UNIT	WALL 9 / 12	OS-SECYH091 / OS-SAAH121												
Available combinations														
Cooling														
Cooling	IU combinations	Cooling capacity						Power input			EER (W/W)	SEER	Energy Class	
		Each room (kW)		Total (kW)			(kW)							
		A	B	min	nominal	max	min	rating	max					
1 unit	9	2.50	—	1.43	2.50	3.20	0.35	0.75	0.91	3.15	—	—		
	12	3.50	—	1.43	3.50	3.90	0.35	1.08	1.29	3.25	—	—		
	18	5.00	—	1.43	5.00	5.10	0.35	1.35	1.69	3.23	—	—		
2 units	9+9	2.65	2.65	2.12	5.30	6.41	0.54	1.64	2.05	3.23	6.10	A++		
	9+12	2.27	3.03	2.12	5.25	6.41	0.54	1.40	2.05	3.74	7.40	A++		
	12+12	2.65	2.65	2.12	5.31	6.41	0.54	1.38	2.05	3.85	7.46	A++		

Available combinations															
Heating															
Heating	IU combinations	Heating capacity						Power input			COP (W/W)	SCOP Average Season	Energy Class Average Season	SCOP Warmer Season	Energy Class Warmer Season
		Each room (kW)		Total (kW)			(kW)								
		A	B	min	nominal	max	min	rating	max						
1 unit	9	3.00	—	1.56	3.00	3.63	0.32	0.80	1.00	3.75	—	—	—	—	
	12	3.80	—	1.56	3.80	4.60	0.32	1.00	1.20	3.81	—	—	—	—	
	18	5.20	—	1.56	5.20	5.79	0.42	1.35	1.88	3.85	—	—	—	—	
2 units	9+9	2.78	2.78	2.23	5.57	6.68	0.51	1.50	1.88	3.71	4.00	A+	5.10	A++	
	9+12	2.39	3.18	2.23	5.54	6.68	0.51	1.39	1.88	3.99	4.25	A+	5.15	A++	
	12+12	2.79	2.79	2.23	5.62	6.68	0.51	1.37	1.88	4.10	4.34	A+	5.28	A++	

Available combinations														
Cooling														
Cooling	IU combinations	Cooling capacity						Power input			EER (W/W)	SEER	Energy Class	
		Each room (kW)		Total (kW)			(kW)							
		A	B	min	nominal	max	min	rating	max					
1 unit	9	2.50	—	1.43	2.50	3.20	0.35	0.75	0.91	3.15	—	—		
	12	3.50	—	1.43	3.50	3.90	0.35	1.08	1.29	3.25	—	—		
	18	5.00	—	1.43	5.00	5.10	0.35	1.35	1.69	3.23	—	—		
2 units	9+9	2.65	2.65	2.12	5.30	6.41	0.54	1.64	2.05	3.23	6.10	A++		
	9+12	2.27	3.03	2.12	5.25	6.41	0.54	1.55	2.05	3.56	6.67	A++		
	12+12	2.65	2.65	2.12	5.31	6.41	0.54	1.55	2.05	3.56	6.65	A++		

Available combinations															
Heating															
Heating	IU combinations	Heating capacity						Power input			COP (W/W)	SCOP Average Season	Energy Class Average Season	SCOP Warmer Season	Energy Class Warmer Season
		Each room (kW)		Total (kW)			(kW)								
		A	B	min	nominal	max	min	rating	max						
1 unit	9	3.00	—	1.56	3.00	3.63	0.32	0.80	1.00	3.75	—	—	—	—	
	12	3.80	—	1.56	3.80	4.60	0.32	1.00	1.20	3.81	—	—	—	—	
	18	5.20	—	1.73	5.20	5.79	0.42	1.35	1.88	3.85	—	—	—	—	
2 units	9+9	2.78	2.78	2.23	5.57	6.68	0.51	1.50	1.88	3.71	3.80	A	5.10	A+++	
	9+12	2.39	3.18	2.23	5.57	6.68	0.51	1.35	1.88	4.12	4.39	A+	5.02	A++	
	12+12	2.79	2.79	2.23	5.54	6.68	0.51	1.38	1.88	4.02	4.35	A+	4.95	A++	

MULTISPLIT TRIAL 21

Available combinations														
Cooling														
Cooling	IU combinations	Cooling capacity						Power input			EER (W/W)	SEER	Energy Class	
		Each room (kW)		Total (kW)			(kW)							
		A	B	C	min	nominal	max	min	rating	max				
2 units	12	3.50	—	—	1.43	3.50	3.90	0.38	1.08	1.30	3.23	—	—	
	18	5.00	—	—	1.65	5.00	6.00	0.48	1.35	1.78	3.28	—	—	
	9+9	2.65	2.65	—	2.05	5.30	6.41	0.57	1.64	2.08	3.23	5.60	A+	
2 units	9+12	2.57	3.43	—	2.01	6.00	6.59	0.57	1.85	2.12	3.23	5.60	A+	
	9+18	2.03	4.07	—	2.01	6.25	6.83	0.57	1.74	2.17	3.59	6.30	A++	
	12+12	3.05	3.05	—	2.01	6.10	6.83	0.57	1.80	2.17	3.23	5.60	A+	
3 units	9+9+9	2.03	2.03	2.03	2.44	6.10	7.32	0.68	1.89	2.36	3.23	6.10	A++	
	9+9+12	1.86	1.86	2.48	2.48	6.20	7.44	0.63	1.79	2.16	3.58	6.62	A++	

Available combinations															
Heating															
Heating	IU combinations	Heating capacity						Power input			COP (W/W)	SCOP Average Season	Energy Class Average Season	SCOP Warmer Season	Energy Class Warmer Season
		Each room (kW)		Total (kW)			(kW)								
		A	B	C	min	nominal	max	min	rating	max					
2 units	12	3.80	—	—	1.43	3.80	4.60	0.35	1.02	1.23	3.71	—	—	—	
	18	5.20	—	—	1.74	5.20	6.64	0.45	1.40	2.00	3.71	—	—	—	
	9+9	2.95	2.95	—	2.13	5.90	6.77	0.52	1.59	1.91	3.71	3.80	A	—	
2 units	9+12	2.70	3.60	—	2.13	6.30	6.96	0.52	1.70	1.95	3.71	3.80	A	—	
	9+18	2.30	4.40	—	2.13	6.19	7.22	0.52	1.49	2.00	4.15	3.96	A	—	
	12+12	3.15	3.15	—	2.13	6.30	7.22	0.52	1.70	2.00	3.71	3.80	A	—	
3 units	9+9+9	2.15	2.15	2.15	2.36	6.45	7.34	0.63	1.74	2.17	3.71	4.80	A+	4.80	A+++
	9+9+12	1.89	1.89	2.52	2.20	6.29	7.55	0.51	1.43	1.78	4.41	3.95	A	5.42	A+++

Available combinations														
Cooling														
Cooling	IU combinations	Cooling capacity						Power input			EER (W/W)	SEER	Energy Class	
		Each room (kW)		Total (kW)			(kW)							
		A	B	C	min	nominal	max	min	rating	max				

3 units	9-9-9	3.33	3.33	3.33	—	—	2.89	50.00	12.31	0.70	2.60	3.32	3.85	3.20	B	—	—
	9-9-12	3.30	3.30	4.40	—	—	2.89	11.00	12.31	0.70	2.86	3.15	3.85	3.20	B	—	—
	9-9-18	2.88	2.88	5.75	—	—	2.89	11.50	12.31	0.70	2.99	3.12	3.85	3.20	B	—	—
	9-12-12	3.14	4.18	4.18	—	—	2.89	11.50	12.31	0.70	2.99	3.15	3.85	3.20	B	—	—
	9-12-18	2.77	3.09	5.54	—	—	2.89	12.00	12.32	0.70	3.12	3.12	3.85	3.20	B	—	—
	12-12-12	3.83	3.83	3.83	—	—	2.89	11.50	12.31	0.70	2.99	3.25	3.85	3.20	B	—	—
4 units	9-9-9-9	3.00	3.00	3.00	—	—	3.69	12.00	13.54	0.80	3.07	3.65	3.91	3.40	A	—	—
	9-9-9-12	2.77	2.77	2.77	3.09	—	3.69	12.00	13.54	0.80	3.07	3.65	3.91	3.40	A	—	—
	9-9-9-18	2.40	2.40	2.40	4.80	—	3.69	12.00	13.54	0.80	3.07	3.82	3.91	3.40	A	—	—
	9-9-12-12	2.57	2.57	3.43	3.43	—	3.69	12.00	13.54	0.80	3.07	3.65	3.91	3.40	A	—	—
	9-9-12-18	2.25	2.25	3.00	4.50	—	3.69	12.00	13.54	0.80	3.07	3.82	3.91	3.40	A	—	—
	9-12-12-12	2.40	3.20	3.20	3.20	—	3.69	12.00	13.54	0.80	3.07	3.65	3.91	3.40	A	—	—
5 units	9-9-9-9-9	2.66	2.66	2.66	2.66	2.66	4.19	12.31	14.96	0.90	3.32	4.15	3.71	3.80	A	5.10	A+++
	9-9-9-9-12	2.31	2.31	2.31	3.08	3.08	4.19	12.68	14.96	0.90	3.42	4.15	3.71	3.66	A	4.91	A++
	9-9-9-9-18	2.05	2.05	2.05	2.05	4.10	4.19	12.84	14.96	0.90	3.35	4.15	3.83	3.74	A	5.04	A++
	9-9-9-12-12	2.17	2.17	2.90	2.90	4.19	4.19	12.76	14.96	0.90	3.43	4.15	3.72	3.66	A	4.89	A++
	9-9-9-12-18	1.94	1.94	1.94	2.59	3.89	4.19	12.89	14.96	0.90	3.30	4.15	3.80	3.76	A	5.07	A++
	9-9-12-12-12	2.05	2.05	2.74	2.74	2.74	4.19	12.77	14.96	0.90	3.43	4.15	3.72	3.65	A	4.87	A++